ASSIGNMENT 2

CHEMISTRY 302

Due: 4:30 pm Thursday 22 January 2009

- 1. (a) Obtain curves for the effect of the number of air changes per hour (ranging from 0.1 to 5.0 ach in 0.1 ach increments) on the steady-state concentration (in ppmv) of CO_2 in office building under these assumptions. Take the outdoor $p(CO_2)$ as 348 ppmv.
 - (i) Volume = 26,000 m³; rate of CO₂ emissions = 4.3 kg h⁻¹
 - (ii) Volume = 50,000 m³; rate of CO₂ emissions = 1.1 kg h⁻¹
 - (b) An office building of volume 33,000 m³ has a natural infiltration rate of 0.44 ach and a ventilation system that causes a further 1.54 ach. When the ventilation system recirculates 84% of the building air, the steady state concentration is $p(CO_2)$ is 914 ppmv. What portion of fresh air should be used if the $p(CO_2)$ is not to exceed 550 ppmv. Take the outdoor $p(CO_2)$ as 323 ppmv.
 - (c) For the conditions of (b), how long would it take the air to drop from 914 to 600 ppmv?
 - 2. A mobile home has a volume of 148 m^3 and a ventilation rate of 0.55 ach. If the indoor concentration of formaldehyde is 9.2 ppmv, what is the rate of emission of formaldehyde from materials in this home? State any assumptions that you make.